

## PORTABLE FIRE EXTINGUISHERS - MAKE SURE THEY REMAIN READY FOR USE

It does us no good to be trained on how to use a portable fire extinguisher if it is not ready and available for use when needed. So here are a few of the steps we can all take to help ensure we maintain all of our portable fire extinguishers ready for instant use:

- Do not store pallets, tool boxes, trash cans, or any other equipment or materials in front of a portable fire extinguisher. You must always maintain a clear and unobstructed path to portable fire extinguishers at all times.
- Never use a portable extinguisher as a coat rack, nor should you hang equipment or devices such as extension cords or air hoses over an extinguisher. Although it may sound like an easy way to store these items, it will only serve to slow someone down if they need to quickly gain access to the extinguisher to put out a fire.
- Once a year our extinguishers receive a thorough maintenance inspection and then get tagged by an outside inspection company. Make sure the inspection tags remain attached to extinguishers, and report any untagged extinguisher to your supervisor so we can make certain it has been inspected.



- We **must** also conduct a visual inspection of each extinguisher at least once a month. So help out on occasion, and check extinguishers in your area for damage or deterioration. Also make sure the needle on pressure-activated extinguishers is pointing into the green “FULL” portion of the dial, and report any that are not so we can get them recharged.

# SAFETY TALK

NORTH DAKOTA STATE UNIVERSITY • UPPER GREAT PLAINS TRANSPORTATION INSTITUTE • NORTH DAKOTA LOCAL TECHNICAL ASSISTANCE PROGRAM

- Once someone uses an extinguisher to fight a fire, it **must** be turned in for inspection and recharging. In fact, turn it in even if you only pull out the retainer pin but do not actually discharge the extinguisher. That is because you may have inadvertently broken the seal that maintains pressure inside the extinguisher, which could cause it to lose pressure and not function as intended in the future
- If you have a fire extinguisher inside the cab of your equipment, make sure it is securely mounted. This will prevent it from being a flying object that could cause severe injury.

## Action Items:


- ✓ Anytime you see a portable fire extinguisher that is inaccessible, not fully charged, or just looks like it may have been damaged in some way, please rectify the problem or let your supervisor know right away so we can take care of the problem. And the same thing applies if you ever notice that an extinguisher is not hanging in its designated place.
- ✓ Check all fire extinguishers in equipment – make sure they mounted securely.



*Safety Talks are published by NDLTAP in cooperation with the National Local Technical Assistance Association and participating partner organizations.*



NDSU does not discriminate in its programs and activities on the basis of age, color, gender expression/identity, genetic information, marital status, national origin, participation in lawful off-campus activity, physical or mental disability, pregnancy, public assistance status, race, religion, sex, sexual orientation, spousal relationship to current employee, or veteran status, as applicable. Direct inquiries to: Vice Provost, Title IX/ADA Coordinator, Old Main 201, 701-231-7708, [ndsu.eoaa@ndsu.edu](mailto:ndsu.eoaa@ndsu.edu)



Safety Talk Sign-in Sheet Topic:  
PORTABLE FIRE EXTINGUISHERS - MAKE SURE THEY REMAIN READY FOR USE

Agency: \_\_\_\_\_

Crew: \_\_\_\_\_

Supervisor/Talk Leader: \_\_\_\_\_

Date: \_\_\_\_\_

Print Name

Signature

1.	_____	_____
2.	_____	_____
3.	_____	_____
4.	_____	_____
5.	_____	_____
6.	_____	_____
7.	_____	_____
8.	_____	_____
9.	_____	_____
10.	_____	_____
11.	_____	_____
12.	_____	_____